



Bedminster Township Fire Prevention Department
One Miller Lane, Bedminster NJ 07921
(908) 212-7000 ext. 427

Mobile ENCLOSED Food Truck **NJ State Type 1 Annual Permit \$54.00**

Date: _____

Applicant:

Business Name: _____

Food Truck Name (if different than above): _____

Address: _____

Contact Name: _____

Phone: _____ Email: _____

Request for Fire Safety Permit for Mobile Enclosed Food Truck

Event Location: _____

Type of Event: _____

The Food Truck will be used on or between (dates): _____

And between the hours of _____ and _____.

The Food Truck will be set up and ready for inspection on Date/Time: _____
_____.

Name and phone number of contact/ responsible person to be present at the time of the
inspection: _____



Bedminster Township Fire Prevention Department
One Miller Lane, Bedminster NJ 07921
(908) 212-7000 ext. 427

Vehicle Information

Vehicle Registration (License #): _____ State: _____

Is this Vehicle equipped with an exhaust hood: Yes No

Cooking Appliances:

Stove Griddle Oven Deep Fryer Other _____

- Cooking operations that produce grease laden vapors, must be equipped with an exhaust hood and a hood fire suppression system.
- The Fire Suppression System must have a valid inspection tag. Hood fire suppression systems are required to be inspected every 6 months. The Operator must have a copy of the actual fire suppression system inspection report (not just a tag) and submit with application.
- If the truck has a deep fat fryer, the vehicle must be equipped with a "K-type" portable fire extinguisher. Other trucks must have a fire extinguisher compatible with the fire suppression system. All fire extinguishers must have a current service tag,
- Propane cylinders, piping and hoses must be in good condition and free from leaks.

Health Department: Temporary cooking operations require a Health Permit from Somerset County Health Department

I hereby acknowledge that I have read this application, that the information given is correct, and that I am the owner, or duly appointed person, authorized to act in the owner's behalf and as such hereby agree to comply with the applicable requirements of the Fire Code as best as any specific conditions imposed by the Fire Official.

Applicant Signature

Name/ Title

Date

FOR OFFICE USE ONLY

Date Paid: _____ Amount Paid: _____ Check Number: _____ Permit #: _____



Bedminster Township Fire Prevention Department
One Miller Lane, Bedminster NJ 07921
(908) 212-7000 ext. 427

- Food Truck vendors can apply for an annual Type 1 Permit.
- Food Trucks shall be ***CONTACT THE FIRE PREVENTION DEPARTMENT*** each and every time they operate in Bedminster Township.
- A copy of the Somerset County Health Permit must be submitted to Bedminster Fire Prevention.
- Fire Official and Fire Inspectors will use the NFPA Food Truck Safety Fact Sheet and checklists pertaining to, but not limited to General Safety, Fuel and Power Sources, Propane System Integrity, Operation Safety, and Solid Fuel Safety. <https://www.nfpa.org/-/media/Files/Public-Education/By-topic/Food-trucks/FoodTruckFactSheet.pdf>
- Propane Tanks:
 - Must be secured at all times
 - All fittings and connections must be tight and tested for leaks
 - Shall be clearly labeled if inside a cabinet
- Kitchen fire suppression system:
 - Shall have a valid service tag (within 6 months)
 - Shall have a copy of the most recent inspection report (within 6 months) and submit a copy to The Bedminster Township Fire Official
- Kitchen ventilation exhaust hood and filters shall be clean of any grease residue.
- Fuel for portable generators must be stored in the appropriate fuel container.
- Fire extinguisher:
 - Commercial grade ABC extinguisher required
 - Shall have a valid service tag (within 1 year)
 - Needle must be in the green
 - Class K extinguisher needed if cooking produces grease laden vapors
- Food Trucks must be parked at least 10 feet from any building, structure, vehicle, or combustible materials.

Required to follow all applicable code requirements in the New Jersey Uniform Fire Code as well as the International Fire Code 2015, New Jersey Edition